



# FACILITATION PLL



0000163264

RECEIVED

May 21, 2015

2015 MAY 22 A 10:47

AZ CORP COMMISSION  
DOCKET CONTROL

Docket Control  
Arizona Corporation Commission  
1200 West Washington Street  
Phoenix, AZ 85007

RE: Baca Float Water Company, Inc.'s Supplemental Response  
to Commission Staff Report  
Docket Nos. WS-01678A-14-0424 and WS-01678A-14-0425

Dear Sir or Madam,

Attached please find Response Schedule 9 as a supplement to Baca Float Water Company, Inc.'s ("Baca Float") filing on May 13, 2015, in response to the ACC Staff Report filed on May 1, 2015. The Company's management believed a fairly new and well-constructed water system should not have a water loss amount that high and conducted an investigation into the test year reported water pumped amounts.

Baca Float did indeed determine that the water pumped amounts included in the application were overstated due to duplication of pumping data included in the totals.

Based on the above explanation and the attached revised water use data sheet for the test year, Baca Float requests the Commission reject Staff recommendation #6 regarding water loss reporting, as it is not necessary at this time.

In addition, Baca Float has contacted ADWR and ADEQ and has resolved all issues related to Staff recommendation #1. Once the appropriate paperwork has been received from each entity, it will be filed with Docket Control.

If you have any questions, please do not hesitate to contact me or the utility directly.

Sincerely,

Sonn S Ahlbrecht  
Certified Public Accountant

enc

ORIGINAL

Arizona Corporation Commission  
DOCKETED

MAY 22 2015

DOCKETED BY	DAB
-------------	-----

**WATER USE DATA SHEET BY MONTH FOR TEST YEAR 2013**

MONTH	NUMBER OF CUSTOMERS	GALLONS SOLD (Thousands)	Original			Amended		
			GALLONS PUMPED (Thousands)	Difference (gallons)	Difference (percentage)	GALLONS PUMPED (Thousands)	Difference (gallons)	Difference (percentage)
JANUARY	397	1,677	1,887	210	11.13%	1,839	162	8.81%
FEBRUARY	397	1,386	1,566	180	11.49%	1,545	159	10.29%
MARCH	398	1,714	1,910	196	10.26%	1,836	122	6.64%
APRIL	399	1,927	2,024	97	4.79%	1,997	70	3.51%
MAY	398	2,017	2,440	423	17.34%	2,131	114	5.35%
JUNE	400	2,119	2,283	164	7.18%	2,183	64	2.93%
JULY	400	1,854	2,381	527	22.13%	2,076	222	10.69%
AUGUST	400	1,866	2,081	215	10.33%	1,996	130	6.51%
SEPTEMBER	399	1,888	2,179	291	13.35%	2,078	190	9.14%
OCTOBER	401	1,935	2,229	294	13.19%	2,178	243	11.16%
NOVEMBER	404	1,757	1,926	169	8.77%	1,923	166	8.63%
DECEMBER	403	1,573	1,714	141	8.23%	1,714	141	8.23%
<b>TOTALS</b>		<b>21,713</b>	<b>24,620</b>	<b>2,907</b>	<b>11.81%</b>	<b>23,496</b>	<b>1,783</b>	<b>7.59%</b>

Originally, Baca Float had reported water sold and water pumped for the test year that resulted in water loss of 11.81%. In this amended filing, the correct amount of water pumped of 23,496 versus the water sold amount of 21,713 (unchanged) results in a loss of 1,783 thousand gallons, or 7.59%.